



LUMINAIRE PHOTOMETRIC TEST REPORT

NAME: 95Livial60/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA			
MODEL	95Livial60/BL	Imax(cd)	396.6	S/MH(C0/180)	1.20
NOMINAL POWER(W)	10	LOR(%)	82.0	S/MH(C90/270)	1.21
RATED VOLTAGE(V)	230	TOTAL FLUX(lm)	799.15	η UP,DN(C0-180)	0.0,39.8
NOMINAL FLUX(lm)	975	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,42.2
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	230	η down (%)	82.0	CIBSE SHR MAX	1.30



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:19 December 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	386.8	385.2	384.3	384.1	386.2	387.9	387.9	388.4	0- 10	37.30	37.30	4.67,3.83
20	361.5	358.5	356.1	354.8	359.8	364.2	363.9	365.7	10- 20	105.9	143.2	17.9,14.7
30	317.1	311.3	308.6	308.0	317.6	321.8	321.7	323.2	20- 30	156.7	299.9	37.5,30.8
40	250.4	244.5	242.2	242.2	252.4	258.6	260.3	260.0	30- 40	178.5	478.4	59.9,49.1
50	163.1	159.1	158.7	157.5	165.5	174.0	177.1	172.9	40- 50	161.9	640.3	80.1,65.7
60	69.05	70.22	71.53	70.48	79.38	83.18	82.50	80.19	50- 60	106.1	746.4	93.4,76.6
70	17.98	17.99	19.26	18.20	21.04	23.34	23.68	21.67	60- 70	44.30	790.7	98.9,81.1
80	0.5520	0.5328	0.4907	0.3289	0.4623	0.7872	0.9012	0.9940	70- 80	8.145	798.9	100,81.9
90	0.1710	0.1787	0.1773	0.1675	0.1202	0.1246	0.1255	0.1318	80- 90	0.2793	799.1	100,82
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 564.08 lm

%lum = 70.6%

%lamp = 57.9%

Conical surface Flux(130deg): 774.98 lm

%lum = 97.0%


%lamp = 79.5%

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:19 December 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

NAME: 95Livia160/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	309	253
80	341	297
75	2230	2132
70	5639	5915
65	9982	9963
60	14809	15030
55	20887	20670
50	27206	25933
45	31805	30014

C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3°C
 Operators:
 Test Date: 19 December 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

WEC AND CCEC

NAME: 95Livial60/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)									
0.0																
1.0	.194	.110	.035	.188	.107	.034	.177	.102	.033	.168	.097	.031	.159	.092	.030	
2.0	.191	.104	.032	.186	.102	.032	.177	.098	.030	.168	.094	.030	.160	.091	.029	
3.0	.182	.097	.029	.178	.095	.029	.170	.092	.028	.163	.089	.027	.156	.086	.027	
4.0	.173	.090	.026	.169	.089	.026	.162	.086	.026	.156	.084	.025	.149	.081	.025	
5.0	.163	.083	.024	.160	.082	.024	.154	.080	.024	.148	.078	.023	.143	.076	.023	
6.0	.154	.077	.022	.151	.076	.022	.146	.075	.022	.141	.073	.021	.136	.071	.021	
7.0	.146	.072	.020	.143	.071	.020	.138	.070	.020	.133	.068	.020	.129	.067	.020	
8.0	.138	.067	.019	.135	.067	.019	.131	.065	.019	.127	.064	.019	.123	.063	.018	
9.0	.130	.063	.018	.128	.062	.018	.124	.061	.017	.120	.060	.017	.117	.059	.017	
10.0	.124	.059	.016	.122	.059	.016	.118	.058	.016	.115	.057	.016	.111	.056	.016	

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.156	.156	.156	.133	.133	.133	.091	.091	.091	.052	.052	.052	.017	.017	.017	
1.0	.144	.129	.115	.123	.110	.099	.084	.076	.068	.048	.044	.040	.015	.014	.013	
2.0	.135	.108	.086	.115	.093	.075	.079	.065	.052	.046	.038	.030	.015	.012	.010	
3.0	.127	.093	.066	.109	.081	.058	.075	.056	.040	.043	.033	.024	.014	.011	.008	
4.0	.121	.082	.052	.104	.071	.046	.071	.049	.032	.041	.029	.019	.013	.009	.006	
5.0	.115	.073	.042	.099	.063	.037	.068	.044	.026	.039	.026	.015	.013	.008	.005	
6.0	.110	.066	.035	.094	.057	.031	.065	.040	.022	.038	.024	.013	.012	.008	.004	
7.0	.104	.060	.030	.090	.052	.026	.062	.037	.018	.036	.022	.011	.012	.007	.004	
8.0	.100	.056	.025	.086	.048	.022	.059	.034	.016	.035	.020	.009	.011	.007	.003	
9.0	.095	.052	.022	.082	.045	.019	.057	.031	.014	.033	.019	.008	.011	.006	.003	
10.0	.091	.048	.020	.079	.042	.017	.054	.029	.012	.032	.017	.007	.010	.006	.002	

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:19 December 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

NAME: 95Livial60/BL					TYPE:					WEIGHT: 1				
SPEC.:					DIM.: 145 x10					SERIAL No.: 0				
MFR.: Elmark Industries JSC					SUR.: cilinder					Shielding Angle:				
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3				
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3				
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2				
Room dimensions					Viewed crosswise					Viewed endwise				
x = 2H y = 2H	22.8	24.2	23.1	24.4	24.5	22.8	24.1	23.0	24.3	24.5				
3H	22.9	24.1	23.2	24.4	24.6	22.9	24.1	23.1	24.3	24.5				
4H	22.9	24.0	23.2	24.2	24.5	22.8	23.9	23.1	24.2	24.4				
6H	22.8	23.8	23.1	24.1	24.4	22.7	23.8	23.0	24.0	24.3				
8H	22.7	23.7	23.0	24.0	24.3	22.6	23.7	23.0	23.9	24.2				
12H	22.7	23.6	23.0	23.9	24.2	22.6	23.6	22.9	23.9	24.1				
4H 2H	22.9	24.0	23.2	24.3	24.5	22.8	24.0	23.1	24.2	24.4				
3H	23.0	24.0	23.4	24.3	24.6	23.0	24.0	23.3	24.2	24.5				
4H	23.0	23.9	23.3	24.2	24.5	22.9	23.8	23.3	24.1	24.4				
6H	22.9	23.7	23.3	24.0	24.4	22.8	23.6	23.2	23.9	24.3				
8H	22.8	23.6	23.2	23.9	24.3	22.8	23.5	23.2	23.8	24.2				
12H	22.8	23.4	23.2	23.8	24.2	22.7	23.4	23.1	23.8	24.2				
8H 4H	22.9	23.6	23.3	23.9	24.3	22.8	23.5	23.2	23.9	24.2				
6H	22.8	23.4	23.2	23.8	24.2	22.7	23.3	23.1	23.7	24.1				
8H	22.7	23.2	23.2	23.7	24.1	22.7	23.2	23.1	23.6	24.0				
12H	22.7	23.1	23.2	23.6	24.0	22.6	23.1	23.1	23.5	24.0				
12H 4H	22.8	23.5	23.2	23.8	24.2	22.8	23.4	23.2	23.8	24.2				
6H	22.7	23.2	23.2	23.7	24.1	22.7	23.2	23.1	23.6	24.0				
8H	22.7	23.1	23.2	23.6	24.0	22.6	23.1	23.1	23.5	24.0				
Variations with the observer position at spacings(CIE Pub.117):														
S = 1.0H	+ 1.0 / - 1.3					+ 1.0 / - 1.3								
1.5H	+ 0.6 / - 0.6					+ 0.5 / - 0.5								
2.0H	+ 2.2 / - 3.1					+ 1.9 / - 2.8								

CIE Pub.117, 975.0 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -0.1)
Area: 0.0094985 m2

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:19 December 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

NAME: 95Livial60/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	54	46	41	53	45	41	53	45	40	36
0.80	62	54	49	62	54	49	60	54	49	44
1.00	69	62	57	68	61	57	67	62	56	52
1.25	75	68	63	74	67	63	72	66	62	57
1.50	78	72	68	77	71	67	75	70	66	61
2.00	83	78	74	82	77	73	79	75	72	66
2.50	85	81	77	84	79	76	81	77	75	69
3.00	88	83	80	86	82	79	83	80	77	71
4.00	90	86	84	88	85	82	85	82	80	74
5.00	91	88	86	90	87	85	86	84	82	75
ROOM INDEX	UF(total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:19 December 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

NAME: 95Livia160/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature:25.3°C
 Operators:
 Test Date:19 December 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity:65.0%
 Test Distance:6.265m [K=1.0000]
 Remarks:

AAI Figure

NAME: 95Livial60/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:




Note: The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3°C
 Operators:
 Test Date: 19 December 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

NAME: 95Livial60/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature: 25.3°C
Operators:
Test Date: 19 December 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity: 65.0%
Test Distance: 6.265m [K=1.0000]
Remarks:

LED Avg.L Report

NAME: 95Livial60/BL	TYPE:	WEIGHT: 1
SPEC.:	DIM.: 145 x10	SERIAL No.: 0
MFR.: Elmark Industries JSC	SUR.: cilinder	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	10538
L_0~180 (75) av	2221
L_0~180 (85) av	249
L_90~270 (65) av	10840
L_90~270 (75) av	2619
L_90~270 (85) av	252
L_45 (65) av	10785
L_45 (75) av	2497
L_45 (85) av	253

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 10.0DEG
Test Speed: MEDIUM
Temperature:25.3°C
Operators:
Test Date:19 December 2022

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 10.0DEG
 Test Speed: MEDIUM
 Temperature: 25.3°C
 Operators:
 Test Date: 19 December 2022

γ Range: 0 - 90DEG
 γ Interval: 2.5DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.00.456
 Humidity: 65.0%
 Test Distance: 6.265m [K=1.0000]
 Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```

```

γ Range: 0 - 90DEG
γ Interval: 2.5DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.00.456
Humidity:65.0%
Test Distance:6.265m [K=1.0000]
Remarks:

```